

GENERAL NOTES:

1. FOR ADDITIONAL GENERAL NOTES, SEE DETAIL DU-01.
2. SEE "UNPAVED AREA TRENCH (UAT) (DU-02) DETAIL".

TRANSFORMER PAD NOTES:


1. TRANSFORMER PAD SET AT GRADE 1/4" PER FOOT ABOVE OR BELOW WATER METER SURFACE OR PLANS FOR RETAINING WALL SUBMITTED FOR REVIEW TO THE C.O.R.R.

STREET LIGHTING NOTES:

1. CRITERIA FOR STREET LIGHTING IN NEW DEVELOPMENTS ARE AS FOLLOWS:
 - LOCAL ROADWAY (300-350 FOOT SPACING WITH 100 WATT HIGH PRESSURE SODIUM (HPS) LAMP)
 - COLLECTOR ROADWAY (250-300 FOOT SPACING WITH 100 WATT HPS LAMP)
 - ARTERIAL ROADWAY (200-250 FOOT SPACING WITH 250 WATT HPS LAMP)
2. IN ADDITION TO THE SPACING SHOWN ABOVE, STREET LIGHTS ARE ALSO PROVIDED AT OR NEAR INTERSECTIONS AND AT OR NEAR THE END OF CUL-DE-SACS.

RECORD SIGNED COPY
ON FILE AT PUBLIC WORKS
APPROVED
02-10-06
DATE
THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL.

CITY OF ROUND ROCK
STANDARD UTILITY ASSIGNMENTS
WITHIN RESIDENTIAL DEVELOPMENT
DETAIL

DRAWING NO:
DU-06

ROUND ROCK, TEXAS
PURPOSE. PASSION. PROSPERITY.