



NOTES:

1. REFER TO "STANDARD INSTALLATION DETAIL FOR ONE OR TWO METERS" FOR SERVICE SPECIFICS.
2. METER BOXES SHALL BE SET AS CLOSE TO R.O.W. (R) AS POSSIBLE, WITH NO PART OF BOX WITHIN R.O.W. METER BOXES SHALL BE LEVEL FROM SIDE TO SIDE AND NO MORE THAN 1/4"/FT. SLOPE FROM FRONT TO BACK (OR BACK TO FRONT). GRADING IN P.U.E. AROUND METER BOX SHALL BE 3:1 MAXIMUM AND SHALL BLEND TO OTHER UTILITY APPURTENANCES WITHOUT ABRUPT ELEVATION CHANGES.

RECORD SIGNED COPY
ON FILE AT PUBLIC WORKS
APPROVED
04-01-10
DATE
THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL. (NOT TO SCALE)

CITY OF ROUND ROCK
WATER SERVICE CASING DETAIL

DRAWING NO:
WT-01

ROUND ROCK, TEXAS
PURPOSE. PASSION. PROSPERITY.