



**NOTES:**

1. THREADS ON OUTLET NOZZLES SHALL BE NATIONAL STANDARD THREAD.
2. TEE MAY HAVE FLANGED OUTLET FOR M.J. X FLANGED GATE VALVE OR, ANCHOR (SWIVEL) TEE MAY BE USED WITH M.J. X M.J. GATE VALVE.
3. A BLUE REFLECTIVE DELINEATOR OF TYPE APPROVED BY THE ENGINEER SHALL BE PLACED 2 TO 3 FEET OFFSET FROM THE CENTERLINE OF PAVED STREETS OR PAVED ACCESS WAYS, ON THE SIDE OF AND IN LINE WITH, ALL NEWLY INSTALLED FIRE HYDRANTS.

RECORD SIGNED COPY  
ON FILE AT PUBLIC WORKS  
APPROVED

04-01-10

DATE

THE ARCHITECT/ENGINEER ASSUMES  
RESPONSIBILITY FOR THE APPROPRIATE  
USE OF THIS DETAIL. (NOT TO SCALE)

**CITY OF ROUND ROCK**

**FIRE HYDRANT ASSEMBLY DETAIL**

DRAWING NO:  
WT-05

