



NOTES:

1. FLUSH HYDRANTS SHALL BE MAINGUARD NO. 77 AS MANUFACTURED BY KUPFERLE FOUNDRY CO., ST. LOUIS, MO, OR APPROVED EQUAL.
2. HYDRANT SHALL BE NON-FREEZING, SELF DRAINING TYPE WITH 30" MIN COVER IN UNPAVED AREAS AND 18" MIN BELOW SUBGRADE IN PAVED AREAS.
3. HYDRANTS SHALL BE FURNISHED WITH A 2" MJ INLET, A NON-TURNING OPERATING ROD, AND SHALL OPEN TO THE LEFT.
4. THE OUTLET SHALL BE 2-1/2" NST BRONZE.
5. ALL WORKING PARTS SHALL BE OF BRONZE-TO-BRONZE DESIGN, AND BE SERVICABLE FROM ABOVE GRADE WITH NO DIGGING. HYDRANTS SHALL BE LOCKABLE TO PREVENT UNAUTHORIZED USE

RECORD SIGNED COPY
ON FILE AT PUBLIC WORKS

APPROVED

04-01-10

DATE

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL. (NOT TO SCALE)

CITY OF ROUND ROCK

**DEAD END LINE
BLOW-OFF VALVE
DETAIL**

DRAWING NO:
WT-24

