



NOTES:

1. SEE NOTES #2 THROUGH #10 ON DETAIL WW-01.
2. DROP CONNECTIONS SHALL BE REQUIRED WHENEVER AN INFLUENT SEWER IS LOCATED MORE THAN TWO FEET (2'-0") ABOVE THE MAIN INVERT CHANNEL.
3. WHEN P.V.C. PIPE IS USED IN SANITARY SEWER LINES, SOLVENT TYPE JOINT P.V.C. FITTINGS MAY BE UTILIZED IN THE DROP ASSEMBLY ONLY.

RECORD SIGNED COPY
ON FILE AT PUBLIC WORKS

APPROVED

04-01-10

DATE

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL. (NOT TO SCALE)

CITY OF ROUND ROCK

**PRECAST CONCRETE WASTEWATER
MANHOLE WITH DROP CONNECTION
DETAIL**

DRAWING NO:
WW-02