



**SPL No: SPL-WT-102**  
**PRODUCT: FIRE HYDRANTS**  
**ISSUE DATE: 1/1/2017**

**DEPARTMENT:** UTILITIES AND ENVIRONMENTAL SERVICES  
**SERVICE:** WATER  
**STANDARD DETAIL:** WT-05  
**SPECIFICATION:** 511

PRODUCT	MANUFACTURER	PRODUCT IDENTIFICATION	NOTES
FIRE HYDRANT	AMERICAN FLOW CONTROL	B-84-B	1
	CLOW VALVE CO.	MEDALLION	
	KENNEDY VALVE	K-81A	
	MUELLER CO.	CENTERION	

**REQUIREMENTS:**

PRODUCTS MUST MEET ALL REQUIREMENTS LISTED IN THE CITY OF ROUND ROCK UTILITY CRITERIA MANUAL, TECHNICAL SPECIFICATIONS AND STANDARD DETAILS. ALL PRODUCTS MUST BE SUITABLE FOR USE IN POTABLE WATER.

- 1) FIRE HYDRANTS SHALL BE DRY BARREL, TRAFFIC MODEL, POST TYPE HAVING COMPRESSION TYPE MAIN VALVES WITH 5-1/4IN OPENING, CLOSING WITH LINE PRESSURE.