



**NOTES:**

1. REFER TO "STANDARD INSTALLATION DETAIL FOR ONE OR TWO METERS" FOR SERVICE SPECIFICS.
2. METER BOXES SHALL BE SET AS CLOSE TO R.O.W. (ℙ) AS POSSIBLE, WITH NO PART OF BOX WITHIN R.O.W. METER BOXES SHALL BE LEVEL FROM SIDE TO SIDE AND NO MORE THAN 1/4"/FT. SLOPE FROM FRONT TO BACK (OR BACK TO FRONT). GRADING IN P.U.E. AROUND METER BOX SHALL BE 3:1 MAXIMUM AND SHALL BLEND TO OTHER UTILITY APPURTENANCES WITHOUT ABRUPT ELEVATION CHANGES.

**RECORD SIGNED COPY  
ON FILE AT U&ES DEPARTMENT**

**APPROVED**

**03-01-18**

**DATE**

THE ARCHITECT/ENGINEER ASSUMES  
RESPONSIBILITY FOR THE APPROPRIATE  
USE OF THIS DETAIL. (NOT TO SCALE)

**CITY OF ROUND ROCK**

**DRAWING NO:**  
WT-01

**WATER SERVICE CASING DETAIL**

