



* THREAD TO COMPRESSION BRASS ELBOW ALLOWED IF NECESSARY DUE TO DEPTH LIMITATIONS.

2" TUBING SHALL BE ANNEALED SEAMLESS TYPE "K" COPPER TUBING OR POLY PIPE MEETING THE CURRENT A.S.T.M. B88 STANDARD WITH NO SWEAT OR SOLDERED JOINTS AND WITH POLYETHYLENE WRAP

GALVANIZED IRON PIPE	
AIR VALVE	BALL VALVE
1"	1"
2"	2"

NOTES:

1. AIR RELEASE VALVE VAULT FOR USE IN NON-PAVEMENT AREAS.
2. PIPE SUPPORT TO BE PROVIDED FOR AIR RELEASE VALVE.

RECORD SIGNED COPY ON FILE AT U&ES DEPARTMENT
APPROVED
03-01-18
DATE
 THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS DETAIL. (NOT TO SCALE)

CITY OF ROUND ROCK
1" THRU 2" AIR RELEASE VALVE INSTALLATION DETAIL (DEVELOPED AREAS)

DRAWING NO:
 WT-14
