



NOTES:

1. RESTRAIN ALL PIPE JOINTS ON BURIED BUTTERFLY VALVES.
2. CONCRETE SUPPORT CRADLE AND SUPPORT PAD SHALL BE 3000 P.S.I. READY-MIX CONCRETE WITH A MINIMUM OF 517 POUNDS PER CUBIC YARD TYPE 1 CEMENT AND A MAXIMUM SLUMP OF 4 INCHES.
3. ALL PROPOSED BUTTERFLY VALVE INSTALLATIONS MUST BE APPROVED BY THE CITY ENGINEER.

**RECORD SIGNED COPY
ON FILE AT U&ES DEPARTMENT**

APPROVED

03-01-18

DATE

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL. (NOT TO SCLAE)

CITY OF ROUND ROCK

**DRAWING NO:
WT-23**

BUTTERFLY VALVE DETAIL

