



NOTES:

1. SEE NOTES #2 THROUGH #10 ON DETAIL WW-01.
2. DROP CONNECTIONS SHALL BE REQUIRED WHENEVER AN INFLUENT SEWER IS LOCATED MORE THAN TWO FEET (2'-0") ABOVE THE MAIN INVERT CHANNEL.
3. WHEN P.V.C. PIPE IS USED IN SANITARY SEWER LINES, SOLVENT TYPE JOINT P.V.C. FITTINGS TO BE UTILIZED IN THE DROP ASSEMBLY ONLY. FITTINGS TO BE P.V.C. SDR-35 WITH TWO PART WATER RESISTANT GLUE AT ALL JOINTS.

RECORD SIGNED COPY
ON FILE AT U&ES DEPARTMENT

APPROVED

03-01-18

DATE

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR THE APPROPRIATE
USE OF THIS DETAIL. (NOT TO SCALE)

CITY OF ROUND ROCK

**PRECAST CONCRETE WASTEWATER
MANHOLE WITH DROP CONNECTION
DETAIL**

DRAWING NO:
WW-02

ROUND ROCK TEXAS
UTILITIES AND ENVIRONMENTAL SERVICES