



SPL No: SPL-WT-102
PRODUCT: FIRE HYDRANTS
ISSUE DATE: 9/1/2019

DEPARTMENT: UTILITIES AND ENVIRONMENTAL SERVICES
SERVICE: WATER
STANDARD DETAIL: WT-05
SPECIFICATION: 511

PRODUCT	MANUFACTURER	PRODUCT IDENTIFICATION	NOTES
FIRE HYDRANT	AMERICAN FLOW CONTROL	B-84-B	1
	CLOW VALVE CO.	MEDALLION	
	KENNEDY VALVE	K81-D	
	MUELLER CO.	CENTERION	

REQUIREMENTS:

PRODUCTS MUST MEET ALL REQUIREMENTS LISTED IN THE CITY OF ROUND ROCK UTILITY CRITERIA MANUAL, TECHNICAL SPECIFICATIONS AND STANDARD DETAILS. ALL PRODUCTS MUST BE SUITABLE FOR USE IN POTABLE WATER.

- 1) FIRE HYDRANTS SHALL BE DRY BARREL, TRAFFIC MODEL, POST TYPE HAVING COMPRESSION TYPE MAIN VALVES WITH 5-1/4IN OPENING, CLOSING WITH LINE PRESSURE.