



SPL No: SPL-WT-103
PRODUCT: CASING SPACERS
ISSUE DATE: 11/1/2019

DEPARTMENT: UTILITIES AND ENVIRONMENTAL SERVICES
SERVICE: WATER
STANDARD DETAIL: WT-16
SPECIFICATION: -

PRODUCT	MANUFACTURER	PRODUCT IDENTIFICATION	NOTES
CASING SPACERS	BWM COMPANY	MODEL BWM SS STAINLESS STEEL	1,2,3
	CCI PIPELINE SYSTEMS	MODEL CSS STAINLESS STEEL	
	CASCADE WATERWORKS MFG	MODEL CCS STAINLESS STEEL	
	ADVANCE PRODUCTS AND SYSTEMS, LLC	MODEL SSI	
END SEALS	BWM COMPANY	MODEL BWM PO	4
	CCI PIPELINE SYSTEMS	MODEL ESC	
	CASCADE WATERWORKS MFG	MODEL CCES	
	ADVANCE PRODUCTS AND SYSTEMS, LLC	MODEL AC	

REQUIREMENTS:

PRODUCTS MUST MEET ALL REQUIREMENTS LISTED IN THE CITY OF ROUND ROCK UTILITY CRITERIA MANUAL, TECHNICAL SPECIFICATIONS AND STANDARD DETAILS. ALL PRODUCTS MUST BE SUITABLE FOR USE IN POTABLE WATER.

- 1) SPACERS TO BE T-304 STAINLESS STEEL WITH STAINLESS STEEL HARDWARE
 PIPES UP TO 12" DIAMETER, SPACERS SHALL BE 8" LONG, WITH 1" WIDE RUNNERS MIN.
 PIPES LARGER THAN 12" DIAMETER, SPACERS SHALL BE 12" LONG, WITH 2" WIDE RUNNERS MIN.
- 2) RUNNERS TO BE UHMW (2" MIN. HEIGHT) OR GLASS-REINFORCED NYLON RUNNERS (1.5" MIN. HEIGHT)
- 3) POLY SPACERS, CARBON SPACERS AND SPYDER SPACERS ARE NOT ACCEPTABLE
- 4) END SEALS TO BE SEAMLESS PULL-ON END SEALS WITH STAINLESS STEEL BANDING