



NOTES:

1. UNDERGROUND UTILITIES ARE SHOWN FOR REFERENCE ONLY AND SHALL BE FIELD VERIFIED PRIOR TO BORE.
2. BORE MUST BE OF A SIZE THAT PROPERLY ACCEPTS PRESSURE GROUTING. A MINIMUM OF 2" CLEARANCE SHALL BE REQUIRED AROUND THE INSTALLED DIAMETER OF THE CASING FOR THE FULL LENGTH OF THE BORE.
3. ALL NEW CONDUIT SHALL TRAVERSE UNDERNEATH CITY INFRASTRUCTURE. THIS INCLUDES, BUT IS NOT LIMITED TO, WATER LINES, WASTEWATER LINES, AND STORM SEWER LINES WITH A MINIMUM OUTSIDE-TO-OUTSIDE CLEARANCE OF 18". TRAVERSING ABOVE CITY INFRASTRUCTURE MAY BE ALLOWED, SUBJECT TO APPROVAL OF THE CITY ENGINEER.

SCALE: NTS

RECORD SIGNED COPY ON FILE APPROVED	<h1 style="margin: 0;">CITY OF ROUND ROCK</h1>	DRAWING NO: DU-09 SHEET 1 of 1
01-28-21 DATE	<h2 style="margin: 0;">DRY UTILITY BORE UNDERNEATH EXISTING ROADWAY</h2>	
THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS DETAIL.		