


NOTES:

1. IN LOCATIONS WHERE WALL HEIGHT DOES NOT EXCEED 1 FT., THE WEEP HOLES CAN BE OMITTED.
2. JOINTS IN WALL SHALL MATCH JOINTS IN SIDEWALK.
3. WALL ENDS SHALL BE CHAMFERED.
4. EXPOSED FACE OF WALL SHALL HAVE FORM LINER FINISH IF SHOWN ON THE PLANS.
5. REINFORCING STEEL TO BE GRADE 60.
6. CONCRETE FOR WALL SHALL BE ITEM 421 CLASS 'C', 3,600 PSI AT 28 DAYS.
7. WALL TO BE CONSTRUCTED PER ITEM 423 "RETAINING WALLS" & ITEM 420 "CONCRETE SUBSTRUCTURES".
8. HANDRAIL POSTS SHALL BE GROUTED INTO SLEEVES THAT ARE CAST IN CONCRETE WALL.

SCALE: NTS

RECORD SIGNED COPY ON FILE APPROVED	CITY OF ROUND ROCK	DRAWING NO: ST-08 SHEET 1 of 1
01-28-21 DATE	SHORT WALL DETAIL	
THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR THE APPROPRIATE USE OF THIS DETAIL.		