



**SPL No:** SPL-WT-110  
**PRODUCT:** PVC WATER PIPE  
**ISSUE DATE:** 5/1/2025

**DEPARTMENT:** PUBLIC WORKS  
**SERVICE:** WATER  
**STANDARD DETAIL:** WT-7, WT-8  
**SPECIFICATION:** 510 PIPE

PRODUCT	MANUFACTURER	PRODUCT IDENTIFICATION	NOTES
PVC WATER PIPE (8-inch to 16-inch)	JM EAGLE	UP TO 16"	1-3
	WESTLAKE PIPE & FITTINGS	UP TO 16"	
	DIAMOND PLASTICS CORP.	UP TO 16"	
	VINYLECH CORP	UP TO 12"	
	NORTHERN PIPE PRODUCTS	UP TO 12"	
	JET STREAM	UP TO 12"	
	SANDERSON PIPE CORP.	UP TO 12"	

**REQUIREMENTS:**

PRODUCTS MUST MEET ALL REQUIREMENTS LISTED IN THE CITY OF ROUND ROCK UTILITY CRITERIA MANUAL, TECHNICAL SPECIFICATIONS AND STANDARD DETAILS. ALL PRODUCTS MUST BE SUITABLE FOR USE IN POTABLE WATER.

- 1) ACCEPTABLE PIPE SIZES ARE 8", 12", AND 16"
- 2) WATER PVC PIPE SHALL BE AWWA C900, DR18 (235PSI RATED) UNLESS OTHERWISE NOTED.
- 3) SEE SPL-WT-105 MECHANICAL RESTRAINT FOR EXTERNAL JOINT RESTRAINT DEVICES.