



**SPL No:**               **SPL-WW-107**  
**PRODUCT:**       **GRAVITY PVC PIPE AND FITTINGS**  
**ISSUE DATE:**   **5/1/2025**

**DEPARTMENT:**     PUBLIC WORKS  
**SERVICE:**         WASTEWATER  
**STANDARD DETAIL:** WW-17, WW-18  
**SPECIFICATION:**   510 PIPE

PRODUCT	MANUFACTURER	PRODUCT IDENTIFICATION	NOTES
PVC GRAVITY WASTEWATER PIPE	DIAMOND PLASTICS CORP.	6-INCH AND LARGER	1,2,3
	JM EAGLE	6-INCH AND LARGER	
	WESTLAKE PIPE AND FITTINGS	6-INCH AND LARGER	
	JET STREAM	6-INCH AND LARGER	
	VINYLTECH CORP.	6-INCH AND LARGER	
	SANDERSON PIPE	6-INCH - 15-INCH	
	NORTHERN PIPE PRODUCTS	6-INCH AND LARGER	
PVC WASTEWATER FITTINGS	TIGRE-ADS	-	1,2
	THE HARRINGTON CORP.	-	
	WESTLAKE PIPE AND FITTINGS	-	
	GPK PRODUCTS, INC.	-	
	MULTI-FITTINGS CORP.	-	
	SPECIFIED FITTINGS, INC.	-	

**REQUIREMENTS:**

PRODUCTS MUST MEET ALL REQUIREMENTS LISTED IN THE CITY OF ROUND ROCK UTILITY CRITERIA MANUAL, TECHNICAL SPECIFICATIONS AND STANDARD DETAILS. ALL PRODUCTS MUST BE SUITABLE FOR USE IN WASTEWATER APPLICATIONS.

- 1) ACCEPTABLE PIPE SIZES ARE 6" MIN. (SERVICE LATERALS ONLY), 8", 12", 15", 18", 21", 24" AND LARGER IN 6" INCREMENTS.
- 2) GRAVITY PVC PIPE AND FITTINGS TO MEET ASTM D3034.
- 3) GRAVITY PVC WASTEWATER MAINS TO BE SDR 26 UNLESS OTHERWISE NOTED.